

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 11/07/2025

It is certified that an inspection team headed by City Municipal Council, Shahapur

(Name of Officers with designation) from (11/07/2025) Behaadh, PHED

inspected the Commissioner CMC Shahapur

(Name & Address of the school) on 11/07/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. dated 14/8/2023

of UNIVERSITY OF Agricultural Sciences (PHED Lab) certified that

the Sri Sai Vidyaniketan Residential School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 11-07-2026

Signature with Seal:

Name:

Designation:

Name & Address of the Office / Department:

To Sri Sai Vidyaniketan Residential School, Diggi Road, Shahapur

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

UNIVERSITY OF AGRICULTURAL SCIENCES, RAICHUR
COLLEGE OF AGRICULTURE, BHEEMARAYANGUDI

Date: 14-08-2023


Analysis Report of Water Quality

- | | | |
|-----------------------------------|---|--|
| 1. Sample collected By | : | Principal |
| 2. Place/Village | : | Sri Sai Vidyaniketan Residential School,
Diggi Road, Shahapur |
| 3. Type of water sample | : | R O Water |
| 4. Particular of Sample Collected | : | Grab Sample |
| 5. Sample description/condition | : | Good/Satisfactory |
| 6. Date of Sample Receipt | : | 14-08-2023 |
| 7. Analysis Starting Date | : | 14-08-2023 |
| 8. Analysis Completion Date | : | 14-08-2023 |
| 9. Sample Tested as Received | : | |

RESULTS

Sl.No	Parameter	Unit	Result	BIS Standards
1	pH	-	7.60	6.5-8.5
2	Electrical Conductivity	$\mu\text{S}/\text{cm}$	134	-
3	Total Dissolved Solids	mg/L	80.4	500
4	Total Hardness	mg/L	14	300
5	Chloride	mg/L	21.27	250
6	Fluoride	mg/L	0.61	0.62-1.5

Inference: As per the Bureau of Indian Standards for drinking water, concentrations of all the parameters were within the permissible level. Therefore, water can be used for drinking and domestic purpose..


Assistant Professor
Environmental Science
College of Agriculture
Bheemarayanagudi-585287

Note: This certificate is issued for advisory purpose only.



TALUKA HEALTH OFFICE, SHAHAPUR DIST.YADGIR

Email : thoshahapur@gmail.com

No : tho/shp/ /2024-25

Date : 17-01-2025.

SANITORY CERTIFICATE.

This Is to Certify Thast I have Inspected the Exiting Building Sri Sai Vidyaniketan Residential School Shahapur Situted at Diggi Road Shahapur Affiliation 830815 New Delhi. This School Consist Well Ventilated Class Rooms With Suitable Furniture. The Driking Water Arrangements Like Urinalsand Latrines are also Satificactory. There is No Objection for public health point of View to Run The School, For the Academic Year 2024-25 To 2025-26.

Your Faithfully


Taluka Health Officer Shahapur
Tq Shahapur Dist.Yadgir.

To,
Sri Sai Vidyaniketan Residential School
Diggi Road Shahapur.

Copy To

1) Office Copy